



## INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

### Scope of Accreditation

**Accredited Legal Entity:** CSA Group Testing & Certification Inc.

Contact Name: Benjamin Barker

Address: 178 Rexdale Boulevard, Toronto, Ontario M9W 1R3

Telephone: +1 416 747 4013

Website: [www.csagroup.org](http://www.csagroup.org)

Email: [Benjamin.Barker@csagroup.org](mailto:Benjamin.Barker@csagroup.org)

<b>SCC File Number:</b>	06001
<b>Accreditation Standards:</b>	ISO/IEC 17020:2012 SCC Requirements and Guidance – Inspection Body Accreditation Program
<b>Accreditation Sub-Programs:</b>	SPE-1000 Field Evaluation/Special Inspection SPE-3000 Field Evaluation/Special Inspection
<b>Initial Accreditation Date:</b>	2005-01-06
<b>Date of Most Recent Reaccreditation:</b>	2017-05-22
<b>Accreditation Expiry Date:</b>	2021-01-06

#### Additional Fixed Office Locations:


Location	Country	Address	City
B	Canada	1707-94 Street North West Edmonton, AB T6N 1E6	Edmonton
C	Canada	865 Ellingham Avenue Pointe Claire, PQ H9R 5E8	Pointe Claire
D	Canada	13799 Commerce Parkway Richmond, BC V6V 2N9	Richmond
E	USA	5970 Fairview Road Suite 722 Charlotte, NC 28210	Charlotte
F	USA	8501 East Pleasant Valley Road Cleveland, OH 44131-5575	Cleveland





Location	Country	Address	City
G	USA	2860 Guildler Dr Plano, TX 75074	Plano
H	USA	34 Bunsen Irvine, CA 92618	Irvine

**Scope of Accreditation:**

**I: Electric Products Program**


<b>Base program:</b>	SPE-1000 Field Evaluation/Special Inspection
<b>Inspection Standards</b>	CSA Model Code SPE-1000 Canadian Electrical Code
<b>Inspection Label</b>	 <p><i>The label presented above is in accordance with CSA SPE-1000 and is effective as of April 01, 2015.</i></p> <p><i>Product inspected to CSA SPE-1000 between April 1st, 2010 and April 1st, 2015 was labeled in accordance with CSA SPE-1000 as represented by the labels below.</i></p>



	 <p><i>Product inspected to CSA SPE-1000 prior to April 1st, 2010 was labeled in accordance with CSA SPE-1000-99 as represented by the label below.</i></p> 
<p><b>Locations:</b></p>	<p>A, B, C, D, E, F, G, H</p>
<p><b>Scope of Accreditation</b></p>	<p>The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:</p> <p>As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding</p> <ol style="list-style-type: none"> <li>wire and cable products;</li> <li>wiring devices;</li> <li>equipment for use in hazardous locations;</li> <li>medical electrical equipment and systems;</li> <li>components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;</li> <li>equipment connected to line voltage in excess of 46 kV;</li> <li>manlifts, elevators, climb assists and similar systems (other than their associated control panels); and</li> <li>any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone).</li> </ol> <p>*Field evaluation/special inspection only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.</p>



**II: Medical Electrical Equipment Program**

<b>Base program:</b>	SPE-3000 Field Evaluation/Special Inspection	
<b>Inspection Standards</b>	CSA Model Code SPE-3000 Canadian Electrical Code	
<b>Inspection Label</b>	 <p>The label presented above is in accordance with CSA SPE-3000 and is effective as of June 30, 2016.</p>	
<b>Locations:</b>	A, B, C, D, F, H	
<b>Scope of Accreditation</b>	<p>The performing of field evaluations/special inspections and the application of approval labels on medical electrical equipment (MEE) and medical electrical systems (MES)<sup>+</sup> in accordance with all of the following:</p> <p>As identified in the scope of CSA SPE-3000 Model Code for the field evaluation/special inspection of medical electrical equipment and systems, but excluding the following product categories at this time:</p> <ul style="list-style-type: none"> <li>a) cosmetic and hygiene equipment;</li> <li>b) X-ray equipment and systems;</li> <li>c) MRIs and CT scans; and</li> <li>d) laser equipment.</li> </ul> <p><sup>+</sup>The definitions for medical electrical equipment (MEE) and medical electrical system (MES) can be found in SPE-3000-15 Section 3 Definitions.</p>	



This document forms part of the Certificate of Accreditation issued by the Standards Council of Canada (SCC) to CSA Group Testing & Certification Inc. The original version is available in the Directory of Accredited Inspection Bodies on the SCC website at [www.scc.ca](http://www.scc.ca).

---

Elias Rafoul  
Vice-President, Accreditation Services  
Date: 2018-10-09