



INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

Scope of Accreditation

Accredited Legal Entity: QAI LABORATORIES LTD.

Contact Name: Lawrence Gibson

LOCATION A

Address: 3980 North Fraser Way

Burnaby, BC V5J 5K5

Telephone: +1 604 527 8378

Fax: +1 604 527 8368

Website: <http://www.qai.org>

Email: lgibson@qai.org

SCC File Number:	06008
Accreditation Standards:	ISO/IEC 17020:2012 SCC Requirements and Guidance – Inspection Body Accreditation Program
Accreditation Sub-Programs:	SPE-1000 Field Evaluation/Special Inspection SPE-3000 Field Evaluation/Special Inspection
Initial Accreditation Date:	2010-01-15
Date of Most Recent Reaccreditation:	2017-12-26
Accreditation Expiry Date:	2022-01-15

Additional Fixed Office Locations:



The inspection activities conducted by the above-mentioned legal entity at the following locations are also included in this scope of accreditation:

Scope of Accreditation:

I: Electric Products Program


Base program:	SPE-1000 Field Evaluation/Special Inspection
Inspection	CSA Model Code SPE-1000



Standards	Canadian Electrical Code	
Inspection Label	 <p><i>The label presented above is in accordance with CSA-SPE-1000 and is effective as of 2016-02-01.</i></p>	
	 <p><i>Product inspected to CSA SPE-1000 between 2010-01-15 and 2017-12-31 was labeled in accordance with CSA SPE-1000 as represented by the label above.</i></p>	
Locations:		
Scope of Accreditation	<p>The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:</p> <p>As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding</p> <ol style="list-style-type: none"> wire and cable products; wiring devices; equipment for use in hazardous locations; medical electrical equipment and systems; components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers; equipment connected to line voltage in excess of 46 kV; manlifts, elevators, climb assists and similar systems (other than their associated control panels); and any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone). <p>*Field evaluation/special inspection only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.</p>	



II: Medical Electrical Equipment Program

Base program:	SPE-3000 Field Evaluation/Special Inspection
Inspection Standards	CSA Model Code SPE-3000 Canadian Electrical Code
Inspection Label	 <p><i>The label presented above is in accordance with CSA-SPE-3000 and is effective as of 2017-08-29.</i></p>
Locations:	
Scope of Accreditation	<p>The performing of field evaluations/special inspections and the application of approval labels on medical electrical equipment (MEE) and medical electrical systems (MES)[†] in accordance with all of the following:</p> <p>As identified in the scope of CSA SPE-3000 Model Code for the field evaluation/special inspection of medical electrical equipment and systems, but excluding the following product categories at this time:</p> <ul style="list-style-type: none"> a) cosmetic and hygiene equipment; b) X-ray equipment and systems; c) MRIs and CT scans; and d) laser equipment. <p>[†]The definitions for medical electrical equipment (MEE) and medical electrical system (MES) can be found in SPE-3000-15 Section 3 Definitions.</p>



Standards Council of Canada
Conseil canadien des normes

This document forms part of the Certificate of Accreditation issued by the Standards Council of Canada (SCC) to QAI LABORATORIES LTD. The original version is available in the Directory of Accredited Inspection Bodies on the SCC website at www.scc.ca.

Elias Rafoul
Vice President, Accreditation Services
Date: 2018-05-14