



INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

Scope of Accreditation

Accredited Legal Entity: Underwriters Laboratories of Canada

Contact Name: Andrew Saunders
 Address: 7 Underwriters Road, Toronto, ON, M1R 3A9
 Telephone: +1 416 757 5250
 Fax: +1 416 757 2627
 Email: Andrew.Saunders@ca.ul.com

Accreditation Number:	06002
Initial Accreditation Date:	2004-11-29
Reaccreditation Date:	2012-11-04
Accreditation Expiry Date:	2017-07-07
Accreditation Standards:	ISO/IEC 17020:2012 Requirements and Guidance – Accreditation of Inspection Bodies

Inspection Label:



Note : The Label presented above is in accordance with CSA SPE 1000 and is effective as of August 1, 2016.



Scope of Accreditation:


The performing of field inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:

As identified in the scope of CSA SPE-1000 Model Code for the field evaluation of electrical equipment, but excluding

- a) wire and cable products;
- b) wiring devices;
- c) equipment for use in hazardous locations;
- d) medical electrical equipment and systems;
- e) components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;
- f) equipment connected to line voltage in excess of 46 kV;
- g) manlifts, elevators, climb assists and similar systems (other than their associated control panels); and
- h) any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone).

*Special inspection/field evaluation only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.

Product inspected between May 1, 2015 and August 1, 2016 is labeled in accordance with CSA-SPE-1000 as represented by the label below.





Product inspected between April 1, 2010 and April 30, 2015 is labeled in accordance with CSA-SPE-1000 as represented by the label below.



Product inspected prior to April 01, 2010 was labeled in accordance with CSA-SPE-1000-99 as represented by the label below.

