



TESTING AND CALIBRATION LABORATORY ACCREDITATION PROGRAM (LAP)

Scope of Accreditation

Accredited Laboratory No. 576

Legal Name of Accredited Laboratory: BC Hydro

Location Name or Operating as: POWERTECH LABS INC.

Contact Name: Ian Chang

Address: 12388 88th Avenue, Surrey, BC V3W 7R7

Telephone: 604 598 5128

Fax: 888 590 6501

Website: www.powertechlabs.com

Email: ian.chang@powertechlabs.com

SCC File Number:	15669
Accreditation Standard(s):	ISO/IEC 17025:2005
Fields of Testing:	Chemical/Physical Electrical/Electronic Mechanical/Physical
Program Specialty Area:	Environmental Testing (ET)
Initial Accreditation:	2005-01-13
Most Recent Accreditation:	2020-08-25
Accreditation Valid to:	2021-10-02



CONSTRUCTION

Road and Railway & Civil Constructions:

Dams

USACE CERL TR 99/104	Greaseless Bushings for Hydropower Applications
----------------------	---

ELASTOMERS AND PROTECTIVE (AND OTHER) COATINGS

Paints, Varnishes, Inks, Coatings, and Allied Products:

ASTM B117	Standard Practice for Operating Salt Spray (Fog) Apparatus
ASTM G154	Standard Practice for Operating Fluorescent Ultraviolet (UV) Lamp Apparatus for Exposure of Nonmetallic Materials
ISO 9227	Corrosion tests in artificial atmospheres - Salt spray tests

Plastics, Resins and Rubbers:

ASTM D412	Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers – Tension Only for: 9, test method A
ASTM D572	Standard Test Method for Rubber - Deterioration by Heat and Oxygen Only for: 10.2 and 10.4
ASTM D638	Standard Test Method for Tensile Properties of Plastics
ASTM D785	Standard Test Method for Rockwell Hardness of Plastics and Electrical Insulating Materials Only for: 11, procedure A, Rockwell Hardness Scale R & M
ASTM D2240	Standard Test Method for Rubber Property - Durometer Hardness Only for: 3.0 and 9.2
ASTM D3418	Standard Test Method for Transition Temperatures and Enthalpies of Fusion and Crystallization of Polymers by Differential Scanning Calorimetry Only for: 10.2 For Glass Transition

ELECTRICAL PRODUCTS AND ELECTRONIC PRODUCTS

Communications Equipment and Systems:

Components and Assemblies

DNVGL-CG-0339	Environmental test specification for electrical, electronic and programmable equipment and systems Only for: Clause 6 Vibration tests, except for Table 9 Extreme vibration strain
IEC 60068-2-27	Environmental Testing – Part 2-27: Tests - Test Ea and guidance: Shock



IEC 60068-2-6	Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)
IEC 60068-2-64	Environmental testing - Part 2-64: Tests – Test Fh: Vibration, broadband random and guidance
IEC 60945	Maritime navigation and radiocommunication equipment and systems - General requirements - Methods of testing and required test results Only for: Clause 8.7 Vibration
IEC 61373	Railway applications - Rolling stock equipment - Shock and vibration tests

Power and Signal Distribution Equipment

OpenADR VEN	OpenADR Alliance Virtual End Node (VEN) Certification Test
OpenADR VTN	OpenADR Alliance Virtual Top Node (VTN) Certification Test

Telecommunications Equipment

AeroMACS RCT WMF-T25-006	WiMAX Forum® AeroMACS Radio Conformance Tests
AeroMACS PCT WMF-T25-008	WiMAX Forum® Test Suite Structure and Test Purposes (TSS&TP) Specification

Components and Assemblies:

(Electrical Rotating Machines)

IEEE 1043	IEEE Recommended Practice for Voltage Endurance Testing of Form-Wound Bars and Coils
IEEE 1310	IEEE Recommended Practice for Thermal Cycle Testing of Form-Wound Stator Bars and Coils for Large Rotating Machines
IEEE 1553	IEEE Standard for Voltage Endurance Testing of Form-Wound Coils and Bars for Hydrogenerators

Insulators

ANSI C29.1	American National Standard for Electrical Power Insulators - Test Methods Only for: Clause 4.2 Low-Frequency Dry Flashover Voltage Tests Clause 4.3 Low-Frequency Wet Flashover Voltage Tests Clause 4.4 Low-Frequency Dry Withstand Voltage Tests Clause 4.5 Low-Frequency Wet Withstand Voltage Tests Clause 4.7 Impulse Flashover Voltage Tests Clause 4.8 Impulse Withstand Voltage Tests Clause 4.9 Radio Influence Voltage
------------	---



Switches and Controls

ANSI/NEMA C37.54	Indoor Alternating Current High-Voltage Circuit Breakers Applied as Removable Elements in Metal-Enclosed Switchgear -Conformance Test Procedures Only for: Clause 3.5 Lightning Impulse Withstand Voltage Tests Clause 3.6 Continuous Current Carrying Tests Clause 3.8 Load Current Switching Tests Clause 3.9 Short Time Current Carrying Tests Clause 3.10 Short-Circuit Current Tests Clause 6.2 Power Frequency Withstand Voltage Tests
ANSI/NEMA C37.55	Switchgear - Medium Voltage Metal-Clad Assemblies - Conformance Test Procedures Only for: Clause 5.5.2 Power-Frequency Withstand Voltage Tests Clause 5.5.3 Lightning Impulse Withstand Tests Clause 5.7 Continuous Current Test Clause 5.8 Short-Time Withstand Current Test Clause 5.9 Momentary Withstand Current Test
ANSI/NEMA C37.57	Metal-Enclosed Interrupter Switchgear Assemblies - Conformance Testing Only for: Clause 4.5.2 Power-Frequency Withstand Voltage Tests Clause 4.5.3 Lightning-Impulse Withstand Test Clause 4.7 Continuous Current Test Clause 4.8 Short-Time Withstand Current Test Clause 4.9 Momentary Withstand Current Test
ANSI/NEMA C37.58	Indoor AC Medium-Voltage Switches for Use in Metal-Enclosed Switchgear - Conformance Test Procedures Only for: Clause 4.5 Lightning Impulse Withstand Test Clause 4.6 Continuous Current Test Clause 4.7.2 Momentary Withstand Current Test Clause 4.7.3 Short-Time Withstand Current Test Clause 4.9 Load-Switching Current Test (If Rated)
CSA C22.2 No. 31	Medium Voltage Metal-Clad Assemblies Only for: Clause 6.1 Temperature Clause 8.5.1 Dielectric strength tests Clause 8.5.2 Impulse tests Clause 8.5.3 Corona-extinction tests Clause 8.5.4 Short-circuit withstand rating



CSA-C22.2 No. 253/ UL 347	Medium-Voltage AC Contactors, Controllers, and Control Centers Only for: Clause 6.2.201 Impulse withstand tests Clause 6.2.202 Power-frequency voltage withstand tests Clause 6.5 Temperature Rise Test Clause 6.6 Short-Time, Momentary and Peak Withstand Current Bus Tests Clause 6.102 Make and Break Capacity Test Clause 6.103 Overload Test Clause 6.104 Fault Interruption Test Clause 6.202 Short Time Capability
IEC 62271-111/ IEEE C37.60	High-voltage switchgear and controlgear - Part 111: Automatic circuit & reclosers and fault interrupters for alternating current systems up to 38 kV Only for: Clause 6.2 Dielectric tests Clause 6.4 Measurement of the resistance of circuits Clause 6.5 Temperature-rise tests Clause 6.6 Short time withstand current and peak withstand current tests Clause 6.101 Line charging current and cable charging current interruption tests Clause 6.102 Making current capability Clause 6.103 Rated symmetrical interrupting current tests Clause 6.106 Partial discharge (corona) tests Clause 6.111.3 Simulated surge arrester operation test Clause 6.112 Condition of recloser/FI after each test of 6.101, 6.103 and 6.104
IEEE 386	IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems above 600 V Only for: Clause 7.6 Short-time current test Clause 7.7 Switching test Clause 7.8 Fault-closure test



IEEE C37.09	<p>Standard Test Procedure For AC High-Voltage Circuit Breakers Rated On A Symmetrical Current Basis</p> <p>Only for: Clause 4.1 Maximum voltage tests</p> <p>Clause 4.2 Power Frequency</p> <p>Clause 4.3 Continuous Current-Carrying Tests</p> <p>Clause 4.4.3 Power Frequency Withstand Voltage Tests</p> <p>Clause 4.4.4 Full-wave lightning impulse withstand voltage tests</p> <p>Clause 4.4.5 Impulse voltage test for interrupters and resistors</p> <p>Clause 4.4.6 Chopped wave lightning impulse withstand voltage tests</p> <p>Clause 4.4.7 Switching impulse voltage withstand tests</p> <p>Clause 4.5 Standard operating duty (standard duty cycle)</p> <p>Clause 4.6 Interrupting time</p> <p>Clause 4.7 TRV</p> <p>Clause 4.8 Short-circuit current interrupting</p> <p>Clause 4.9.1 Load current switching test conditions</p> <p>Clause 4.9.2 Load current endurance switching test</p> <p>Clause 4.12 Out-of-phase switching current</p>
IEEE C37.09a	<p>Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis Amendment 1 - Capacitance Current Switching</p> <p>Only for: Clause 4.10 Capacitance current switching tests</p>
IEEE C37.20.2	<p>Standard for Metal-Clad Switchgear</p> <p>Only for: Clause 6.2.1 Dielectric tests</p> <p>Clause 6.2.2 Rated continuous current tests</p> <p>Clause 6.2.3 Momentary withstand current tests</p> <p>Clause 6.2.4 Short-time withstand current tests</p> <p>Clause 6.2.5 Auxiliary equipment primary disconnecting device momentary current withstand test</p>
IEEE C37.20.3	<p>Standard for Metal-Enclosed Interrupter Switchgear</p> <p>Only for: Clause 6.2 Dielectric tests</p> <p>Clause 6.5 Temperature-rise tests</p> <p>Clause 6.6 Short-time withstand current and peak withstand current tests</p> <p>Clause 6.14.1 Test for bus-bar insulation</p>
IEEE C37.20.4	<p>IEEE Standard for Indoor AC Switches (1 kV to 38 kV) for Use in Metal-Enclosed Switchgear</p> <p>Only for: Clause 6.6 Short-time withstand current and peak withstand current (formerly momentary) tests</p> <p>Clause 6.13 Fault-making test</p> <p>Clause 6.14 Load-switching current test</p> <p>Clause 6.15 Cable-charging current switching test (optional)</p> <p>Clause 6.16 Unloaded-transformer switching test (optional)</p> <p>Clause 6.17 Direct-acting fuse-tripping current test (optional)</p>
IEEE C37.20.7	<p>IEEE Guide for Testing Metal-Enclosed Switchgear Rated Up to 38 kV for Internal Arcing Faults</p> <p>Only for: 5 Arcing Fault</p>



IEEE C37.23	<p>Metal-Enclosed Bus</p> <p>Only for: Clause 6.2.1.1 Power Frequency Withstand Voltage Tests Clause 6.2.1.2 Lightning impulse withstand voltage tests Clause 6.2.1.3 Test for bus-bar insulation, bus-joint insulation, and bus-tap insulation Clause 6.2.2 Continuous-current Clause 6.2.3 Momentary withstand current Clause 6.2.4 Short-time withstand current</p>
IEEE C37.30.1	<p>Standard Requirements for AC High-Voltage Air Switches Rated Above 1000 V</p> <p>Only for: Clause 8.1.1 Power frequency withstand voltage tests Clause 8.1.2 Lightning impulse dry withstand voltage tests Clause 8.1.3 Power frequency and lightning impulse open gap withstand voltage tests Clause 8.1.4 Switching impulse voltage test of switches rated 362 kV and above Clause 8.2 Temperature rise tests Clause 8.3 Short-time Withstand Current Tests Clause 8.4 Fault-making current test Clause 8.7 Corona tests</p>
IEEE C37.41	<p>ANSI/IEEE Standard Design Tests for High-Voltage (>1000 V) Fuses and Accessories</p> <p>Only for: Clause 8.2 Power-frequency dry-withstand voltage tests Clause 8.3 Power-frequency wet-withstand voltage tests on outdoor devices Clause 8.5 Lightning impulse-withstand voltage tests Clause 9 Interrupting tests Clause 11 Temperature-rise tests Annex A.4 Short-time withstand current tests for disconnecting switches Annex A.5 Load-break tests</p>
IEEE C37.42	<p>IEEE Standard Specifications for High-Voltage (> 1000 V) Expulsion-Type Distribution-Class Fuses, Fuse and Disconnecting Cutouts, Fuse Disconnecting Switches, and Fuse Links, and Accessories Used with These Devices</p> <p>Only for: Clause 3.3.1 Dielectric tests Clause 3.3.2 Interrupting [breaking] Clause 3.3.5 Short-time current tests for disconnecting cutouts Clause 3.3.6 Temperature-rise tests</p>
IEEE C37.45	<p>IEEE Standard for Design Test Specifications for High Voltage (> 1000 V) Distribution Class Enclosed Single-Pole Air Switches</p> <p>Only for: Clause 8.1 Dielectric tests Clause 8.3 Short-time current tests Clause 8.4 Temperature-rise tests</p>



IEEE C37.46	Specifications for High-Voltage (>1000 V) Expulsion and Current-Limiting Power Class Fuses and Fuse Disconnecting Switches Only for: Clause 4.1 Dielectric tests Clause 4.2 Interrupting [breaking] Clause 4.4 Temperature-rise
IEEE C37.66	IEEE Standard Requirements for Capacitor Switches for AC Systems (1 kV to 38 kV) Only for: Clause 6.2 Insulation (dielectric) tests Clause 6.3 Short-time current tests Clause 6.4 Rated fault-making current tests
IEEE C37.74	Standard Requirements for Subsurface, Vault, and Pad-Mounted Load-Interrupter Switchgear and Fused Load-Interrupter Switchgear for Alternating Current Systems up to 38 kV Only for: Clause 6.7.2 Dielectric tests Clause 6.7.3 Continuous current test Clause 6.7.4 Short-circuit withstand current tests Clause 6.7.5 Switching tests Clause 6.7.6 Thermal runaway test Clause 6.7.7 Partial discharge tests Clause 6.7.8 DC withstand voltage test
IEEE/IEC 62271-37-013	IEEE/IEC International Standard for High-voltage switchgear and controlgear -- Part 37-013: Alternating-current generator circuit-breakers Only for: Clause 6.2.2.1 Rated power frequency withstand voltage (dry) Clause 6.2.6.2 Lightning impulse voltage test Clause 6.2.12 Sound level tests Clause 6.5 Temperature rise test Clause 6.6 Short-time withstand current and peak withstand current tests Clause 6.103 System-source short-circuit current making and breaking tests Clause 6.104 Load Current Breaking Tests Clause 6.105 Generator-source short-circuit current making and breaking tests Clause 6.106 Out-Of-Phase Current Switching Tests

Transformers

ASTM D3612	Standard test Method for Analysis of Gases Dissolved in Electrical Insulating Oil by Gas Chromatography Except for: Propane and Propylene
IEC 61869-1	Instrument transformers - Part 1: General requirements Only for: Clause 7.2.2 Temperature-rise test Clause 7.2.3 Impulse voltage withstand test on primary terminals Clause 7.2.4 Wet test for outdoor type transformers Clause 7.3.1 Power-frequency voltage withstand tests on primary terminals Clause 7.3.2 Partial discharge measurement Clause 7.3.4 Power-frequency voltage withstand tests on secondary



	<p>terminals</p> <p>Clause 7.3.6 Verification of markings</p> <p>Clause 7.4.1 Chopped impulse voltage withstand test on primary terminals</p>
IEC 61869-3	<p>Instrument transformers - Part 3: Additional requirements for inductive voltage transformers</p> <p>Only for: Clause 7.2.2 Temperature-rise test</p> <p>Clause 7.2.3 Impulse voltage withstand test on primary terminals</p>
IEEE C57.12.90	<p>Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers</p> <p>Only for: Clause 5 Resistance measurements</p> <p>Clause 6 Polarity and phase-relation tests</p> <p>Clause 7 Ratio tests</p> <p>Clause 8 No-load losses and excitation current</p> <p>Clause 9 Load losses and impedance voltage</p> <p>Clause 10 Dielectric tests</p> <p>Clause 11 Temperature-rise tests</p> <p>Clause 12 Short circuit tests</p> <p>Clause 13 Audible sound emissions</p>
IEEE C57.12.91	<p>Standard Test Code for Dry-Type Distribution and Power Transformers</p> <p>Only for: Clause 5 Resistance measurements</p> <p>Clause 6 Polarity and phase relation tests</p> <p>Clause 7 Ratio tests</p> <p>Clause 8 No load losses and excitation current</p> <p>Clause 9 Load losses and impedance voltage</p> <p>Clause 10 Dielectric tests</p> <p>Clause 11 Temperature tests</p> <p>Clause 12 Short circuit tests</p> <p>Clause 13 Audible Sound Level Measurements</p>
IEEE C57.13	<p>Standard Requirements for Instrument Transformers</p> <p>Only for: Clause 8.2 Impedance excitation, and composite error measurements</p> <p>Clause 8.3 Polarity</p> <p>Clause 8.4 Resistance measurements</p> <p>Clause 8.6 Partial discharge measurement</p> <p>Clause 8.9 Measurement of Open-Circuit Voltage of Current Transformers</p> <p>Clause 9.3 Impedance measurements</p> <p>Clause 9.4 Polarity</p> <p>Clause 10.2 Impedance measurements</p> <p>Clause 10.3 Polarity</p> <p>Clause 11.2 Temperature rise tests</p> <p>Clause 11.4 Partial discharge measurement</p> <p>Clause 12.2 Current transformer temperature rise tests</p>



Conductors

CAN/CSA C61089	Round wire concentric lay overhead electrical stranded conductors Only for: Annex B
DS/EN 50182	Conductors for overhead lines – Round wire concentric lay stranded conductors Only for: Annex C
IEC 61089	Round wire concentric lay overhead electrical stranded conductors Only for: Annex B
IEC 61395	Overhead Conductors – Creep test procedures for stranded conductors

Wiring and Related Products

HD 629.1-S3	Test Requirements for accessories for use on power cable of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42) kV – Part1: Accessories for cables with extruded insulation Exception: Table 14
EN 61442	Test methods for accessories for power cables with rated voltages from 6 kV (Um = 7,2 kV) up to 36 kV (Um = 42 kV) Only for: Clause 4 AC voltage tests Clause 6 Impulse voltage tests Clause 7 Partial discharge test Clause 9 Heating cycle voltage test Clause 9.4 Immersion test for outdoor terminations Clause 10 Thermal short-circuit test (screen) Clause 11 Thermal short-circuit test (conductor) Clause 12 Dynamic short-circuit test Clause 13 Humidity and salt fog tests Clause 14 Impact test at ambient temperature

ENVIRONMENTAL AND OCCUPATIONAL HEALTH AND SAFETY

Environmental:

Soil/Sediment (PCB in Soil)

ACTP-6	PCB Content in Soil Samples by Gas Chromatography
--------	---

Soil/Sediment (EPH in Soil)

ACTP-22	Extractable Petroleum Hydrocarbons (EPH) in Solids by GC/FID [BC ENV] EPHs10-19 EPHs19-32
---------	--



Soil/Sediment (Metals in Soil)

EPA 6010D, BC ENV	Strong Acid Leachable Metals (SALM) in Soil by Inductively Coupled Plasma (ICP) [ACTP 25] Aluminum Antimony Arsenic Barium Beryllium Boron Cadmium Chromium Cobalt Copper Iron Lead Lithium Manganese Mercury Molybdenum Nickel Selenium Silver Strontium Sulphur Thallium Thorium Tin Titanium Tungsten Uranium Vanadium Zinc
-------------------	--

Soil/Sediment (PAH in Soil)

ACTP 14	Polycyclic Aromatic Hydrocarbons (PAHs) in Soil by Gas Chromatography-Mass Spectrometry (GC-MS) [BC ENV, EPA 8270D] Acenaphthene, Acenaphthylene, Anthracene, Benzo(a)anthracene, Benzo(a)pyrene, Benzo(b+j)fluoranthene, Benzo(k)fluoranthene, Benzo(g,h,i)perylene, Chrysene, Dibenz(a,h)anthracene, Fluoranthene, Fluorene, Indeno(1,2,3-cd)pyrene, 1-Methylnaphthalene,
---------	--



	2-Methylnaphthalene, Naphthalene, Phenanthrene, Pyrene
--	---

Water (Inorganic)

ACTP 8	pH Value (APHA 4500-H+)
--------	-------------------------

Water (Organic) – (PCB in Water)

ACTP-7	PCB in Aqueous Samples by Gas Chromatography
--------	--

Water (Organic) - (EPH in Water)

ACTP-23	Extractable Petroleum Hydrocarbons (EPH) in Water by GC/FID [BC ENV] EPHw10-19 EPHw19-32
---------	---

Water (Organic) – (PAH in Water)

ACTP 15	Polycyclic Aromatic Hydrocarbons (PAH) in Water by Gas Chromatography-Mass Spectrometry (GC-MS) [BC ENV, EPA 8270D] Acenaphthene, Acenaphthylene, Acridine, Anthracene, Benzo(a)anthracene, Benzo(a)pyrene, Benzo(b+j)fluoranthene, Benzo(k)fluoranthene, Benzo(g,h,i)perylene, Chrysene, Dibenz(a,h)anthracene, Fluoranthene, Fluorene, Indeno(1,2,3-cd)pyrene, 1-Methylnaphthalene, 2-Methylnaphthalene, Naphthalene, Phenanthrene, Pyrene, Quinoline
---------	--

Occupational Health and Safety:

Asbestos

ACTP 10	Asbestos (Bulk) by PLM (NIOSH 9002, EPA 600/R-93/116 Standard, Clauses 2.1, 2.2 & 2.3)
---------	--

Silica

ACTP 12	Respirable Particulate and Silica Analysis by FT-IR [NIOSH 0600, NIOSH 7602]
---------	--



ACTP 27	Respirable Particulate and Silica Analysis by XRD [NIOSH 0600, NIOSH 7500]
---------	--

MACHINERY

Boilers, Pressure Vessels and Piping:

ISO 7866	Gas cylinders - Refillable seamless aluminium alloy gas cylinders - Design, construction and testing Only for: Annex B Test method to determine the sustained-load cracking resistance of aluminium alloy gas cylinders
----------	--

Transportation, Agricultural and Construction Vehicles and Components:

Automobiles, Light Trucks, Vans & Trailers

ANSI HGV 2	Compressed hydrogen gas vehicle fuel containers Only for: Clause 11.3 Leak Test Clause 12.4 Burst Test Clause 12.5 Cycle Test Clause 18.3.2 Ambient Cycling Test Clause 18.3.3 Environmental Test Clause 18.3.4 Extreme Temperature Cycling Clause 18.3.5 Hydrostatic Burst Test Clause 18.3.6 Flaw Tolerance Test Clause 18.3.7 Drop Test Clause 18.3.8 Fire Test Clause 18.3.9 Accelerated Stress Rupture Test Clause 18.3.10 High Strain Rate Impact Test Clause 18.3.11 Permeation Test Clause 18.3.12 Boss Torque Test Clause 18.3.13 Hydrogen Gas Cycling Test Clause 18.3.14 Leak Before Break Test Clause 18.5.2 Ambient Cycling Test Clause 18.5.3 Hydrostatic Burst Test Clause 18.5.4 Container test for performance durability Clause 18.5.5 High strain rate impact test Clause 18.5.6 Permeation test Clause 18.5.7 Container test for expected on-road performance
ANSI HGV 3.1	Fuel system components for compressed hydrogen gas powered vehicles Only for: Clause 5.3 Hydrostatic strength Clause 5.4 Leakage Clause 5.5 Excess torque resistance Clause 5.6 Bending moment Clause 5.7 Continuous operation Clause 5.8.1 Salt spray exposure Clause 5.9 Ultraviolet resistance of external surfaces Clause 5.10 Automotive fluid exposure Clause 5.12 Abnormal electrical voltages Clause 5.13 Vibration resistance Clause 5.15 Insulation resistance Clause 5.16 Pre-cooled hydrogen exposure Clause 8.4.1 Leakage



	<p>Clause 8.4.2 Continuous operation Clause 10.4.1 Continuous operation Clause 10.4.2 Operating torque Clause 11.4.1 Automatic valve Clause 11.4.2 Automatic container valve Clause 13.4.3 Insulation resistance Clause 14.4.1 Hydrostatic strength Clause 14.4.2 External leakage Clause 14.4.3 Continuous operation Clause 14.4.4 Pressure impulse Clause 15.4.1 Hydrostatic strength Clause 15.4.2 Continuous operation Clause 15.4.3 Opening and reseating characteristics</p>
ANSI/CSA HGV 4.4	<p>Breakaway devices for compressed hydrogen dispensing hoses and systems Only for: 2.2 Leakage 2.3 Hydrostatic Strength 2.4 Separation Test 2.5.1 Oxygen Aging Test 2.6 Electrical Conductivity 2.7.1 Deformation 2.7.2 Strength Tests - Impact Test 2.7.3 Drop Test 2.8.1 Pressure Cycle Test</p>
ANSI HPRD 1	<p>Thermally activated pressure relief devices for compressed hydrogen vehicle fuel containers Only for: 7.2 Pressure Cycling 7.3 Accelerated Life 7.4 Thermal Cycling 7.7 UV exposure 7.8.1 Atmospheric exposure (oxygen ageing) 7.10 Impact due to drop and vibration 7.11 Leakage 7.12 Bench top activation 7.13 Flow capacity 7.14 High Pressure activation and flow rate</p>
ANSI NGV 2	<p>Compressed natural gas vehicle fuel containers Only for: Section 11.3 Leak Test Section 12.4 Burst Test Section 12.5 Cycle Test Section 19.3 Ambient Cycling Test Section 19.4 Environmental Test Section 19.5 Extreme Temperature Cycling Section 19.6 Hydrostatic Burst Test Section 19.7 Composite Flaw Tolerance Test Section 19.8 Drop Test *Section 19.9 Bonfire Test Section 19.10 Accelerated Stress Rupture Test *Section 19.11 Penetration Test Section 19.12 Permeation Test Section 19.13 Natural Gas Cycling Test Section 19.14 Leak Before Break Test</p>



ANSI NGV3.1/ CSA 12.3	Fuel System Components for Natural Gas Powered Vehicles Only for: 5.2 Hydrostatic Strength 5.7.2 Salt spray exposure – Salt spray test only 5.8.2 Atmospheric Exposure Test - Oxygen Aging 5.11 Vibration resistance 5.14 Ultraviolet Resistance of External Surfaces 5.15 Automotive fluid exposure
ANSI PRD 1	Pressure relief devices for natural gas vehicle (NGV) fuel containers Only for: 7.7 UV resistance 7.10.2 Impact due to drop and vibration – vibration 7.14.1 Atmospheric exposure - Oxygen Aging
ANSI/CSA HGV 4.10	Standards For Fittings for compressed hydrogen gas and hydrogen rich gas mixtures Only for: 2.3 External Leak Test 2.4 Hydrostatic Burst Test 2.5 Hydraulic Cyclic Endurance Test 2.6 Gas Cyclic Endurance Test 2.8 Explosive Decompression 2.9 Make or Break Test 2.10 Thermal Shock
CSA B51 Part 2	High-Pressure Cylinders for the On-board Storage of Natural Gas as a Fuel for Automotive Vehicles Only for: Clause 14.12 Hydrostatic Pressure Burst Test
EC 79	Implementing Regulation (EC) No 79/2009 of the European Parliament and of the Council on type-approval of hydrogen-powered motor vehicles Annex IV Only for: Part 2, Para. 4.2.1 Burst test Part 2, Para. 4.2.2 Ambient temperature pressure cycle test Part 2, Para. 4.2.3 Leak-before-break (LBB) performance test *Part 2, Para. 4.2.4 Bonfire test *Part 2, Para. 4.2.5 Penetration test Part 2, Para. 4.2.6 Chemical exposure test Part 2, Para. 4.2.7 Composite flaw tolerance test Part 2, Para. 4.2.8 Accelerated stress rupture test Part 2, Para. 4.2.9 Extreme temperature pressure cycle test Part 2, Para. 4.2.10 Impact damage test Part 2, Para. 4.2.11 Leak test Part 2, Para. 4.2.12 Permeation test Part 2, Para. 4.2.13 Boss torque test Part 2, Para. 4.2.14 Hydrogen gas cycling test Part 3, Para. 4.1.1.2(b) Hydrogen compatibility test (non-metallic materials) Part 3, Para. 4.1.2 Ageing test Part 3, Para. 4.2.1 Corrosion resistance test (Test a only) Part 3, Para. 4.2.2 Endurance Part 3, Para. 4.2.3 Hydraulic pressure cycle test Part 3, Para. 4.2.4 Internal leakage test Part 3, Para. 4.2.5 External leakage test
ISO 11114-4	Transportable gas cylinders - Compatibility of cylinder and valve materials with gas contents -Part 4: Test methods for selecting steels resistant to hydrogen embrittlement Only for: Method C - Test method to determine the resistance to hydrogen assisted cracking of steel cylinders
SAE J2600	Compressed hydrogen surface vehicle fueling connection devices



	Only for: Section 5 Type (Design Verification) Tests
UNECE R134	<p>Uniform provisions concerning the approval of motor vehicles and their components with regard to the safety-related performance of hydrogen-fuelled vehicles (HFCV)</p> <p>Only for: Para. 5.1 Verification tests for baseline metrics</p> <p>Para. 5.2 Verification tests for performance durability (sequential hydraulic tests)</p> <p>Para. 5.3 Verification test for expected on-road performance (sequential pneumatic tests)</p> <p>Para. 5.4 Verification test for service terminating performance in fire</p> <p>Para. 9.3.2.1 Rupture test in batch testing</p> <p>Para. 9.3.2.2 Ambient temperature pressure cycling test in batch testing</p> <p>Annex 3, Para. 2 Test procedures for baseline performance metrics</p> <p>Annex 3, Para. 3 Test procedures for performance durability</p> <p>Annex 3, Para. 4 Test procedures for expected on-road performance</p> <p>Annex 3, Para. 5 Test procedures for service termination performance in fire</p> <p>Annex 4, Para. 1.1 Pressure cycling test</p> <p>Annex 4, Para. 1.2 Accelerated life test</p> <p>Annex 4, Para. 1.3 Temperature cycling test</p> <p>Annex 4, Para. 1.7 Drop and vibration test</p> <p>Annex 4, Para. 1.8 Leak test</p> <p>Annex 4, Para. 1.9 Bench top activation test</p> <p>Annex 4, Para. 1.10 Flow rate test</p> <p>Annex 4, Para. 2.1 Hydrostatic strength test</p> <p>Annex 4, Para. 2.2 Leak test</p> <p>Annex 4, Para. 2.3 Extreme temperature pressure cycling test</p> <p>Annex 4, Para. 2.4 Salt corrosion resistance test</p> <p>Annex 4, Para. 2.6(a) Atmospheric exposure test (oxygen)</p> <p>Annex 4, Para. 2.7 Electrical tests</p> <p>Annex 4, Para. 2.8 Vibration test</p> <p>Annex 4, Para. 2.10 Pre-cooled hydrogen exposure test</p>
ISO 19880-3	<p>Gaseous hydrogen - Fueling stations - Part 3: Valves</p> <p>Only for: 5 General test methods</p> <p>6 Check valves</p> <p>7 Excess flow valves</p> <p>8 Flow control valves</p> <p>9 Hose breakaway devices (Except for 9.2.13 Twisting test)</p> <p>10 Manual valves</p> <p>11 Pressure safety valves (PSV)</p> <p>12 Shut-off valves</p>
UN GTR No. 13	<p>Global technical regulation on hydrogen and fuel cell vehicles</p> <p>Part II</p> <p>Only for: Para. 5.1.1 Verification tests for baseline metrics</p> <p>Para. 5.1.2 Verification tests for performance durability (hydraulic sequential tests)</p> <p>Para. 5.1.3 Verification test for expected on-road performance (pneumatic sequential tests)</p> <p>Para. 5.1.4 Verification test for service terminating performance in fire</p> <p>Para. 6.2.2 Test procedures for baseline performance metrics</p> <p>Para. 6.2.3 Test procedures for performance durability</p> <p>Para. 6.2.4 Test procedures for expected on-road performance</p> <p>Para. 6.2.5 Test procedures for service terminating performance in fire</p> <p>Para. 6.2.6.1.1 Pressure cycling test</p>



	Para. 6.2.6.1.2 Accelerated life test Para. 6.2.6.1.3 Temperature cycling test Para. 6.2.6.1.5 Vehicle environment test Para. 6.2.6.1.7 Drop and vibration test Para. 6.2.6.1.8 Leak test Para. 6.2.6.1.9 Bench top activation test Para. 6.2.6.1.10 Flow rate test Para. 6.2.6.2.1 Hydrostatic strength test Para. 6.2.6.2.3 Extreme temperature pressure cycling test Para. 6.2.6.2.4 Salt corrosion resistance test Para. 6.2.6.2.5 Vehicle environment test Para. 6.2.6.2.6(a) Atmospheric exposure test (oxygen) Para. 6.2.6.2.7 Electrical tests Para. 6.2.6.2.8 Vibration tests Para. 6.2.6.2.10 Pre-cooled hydrogen exposure test
--	---

METALLIC ORES AND PRODUCTS

Articles of Metal:

Cast, Forged, Welded or Pressed Metal Components

ASTM E18	Standard Test Methods for Rockwell Hardness of Metallic Materials
ASTM E384	Standard Test Method for Microindentation Hardness of Materials

NONDESTRUCTIVE EXAMINATION

**ASME BPVC-V	ASME Boiler & Pressure Vessel Code, Section V: Nondestructive Examination Only for: Article 2 - Radiographic Examination Article 5 - Ultrasonic Examination Methods for Materials Article 6 - Liquid Penetrant Examination Article 7 - Magnetic Particle Examination
---------------	---

NON-METALLIC MINERALS AND PRODUCTS

Petroleum Refinery Products: (Including asphalt materials; petrochemicals; fuels and lubricants):

Fuels and Lubricants

ASTM D4059	Polychlorinated Biphenyls (PCB) in Oil by Gas Chromatography [ACTP4]
ASTM D664	Acid Number of Petroleum Products by Potentiometric Titration [ACTP 16]
ASTM D7042	Dynamic Viscosity and Density of Liquids by Stabinger Viscometer (and the Calculation of Kinematic Viscosity) [ACTP 17]

Number of Scope Listings: 93



Notes:

ISO/IEC 17025:2005: General Requirements for the Competence of Testing and Calibration Laboratories

AeroMACS: Aeronautical Mobile Airport Communication System

ACTP: Internal Powertech Labs Inc. Procedure (Applied Chemistry Test Procedure)

ASME: American Society of Mechanical Engineers

ASTM: ASTM International, previously American Society for Testing and Materials

BC ENV:

CSA: Canadian Standards Association

DNVGL: Det Norske Veritas (Norway) and Germanischer Lloyd (Germany)

EC: European Environment Agency

EPA: United States Environmental Protection Agency

IEC: International Electrotechnical Commission

IEEE: Institute of Electrical and Electronics

NIOSH: National Institute for Occupational Safety and Health (USA)

UNECE: United Nations Economic Commission for Europe

UN GTR: United Nations Global Technical Regulations

USACE: United States Army Corps of Engineers

(*): These tests are performed in a temporary location (Justice Institute of BC (JI), 13500 256 St, Maple Ridge, BC V4R 1C9; Or Dewdney Creek North PIT #7004 (Off Coquihalla highway, Carolin Mines exit, between Hope and Coquihalla summit).

This document forms part of the Certificate of Accreditation issued by the Standards Council of Canada (SCC). The original version is available in the Directory of Accredited Laboratories on the SCC website at www.scc.ca.

Elias Rafoul
Vice President, Accreditation Services
Publication on: 2020-08-26