



INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

Scope of Accreditation

Accredited Legal Entity: Canadian Standards Association operating as CSA Group

Contact Name: Ben Barker

Address: 178 Rexdale Boulevard
Toronto, Ontario M9W 1R3

Telephone: +1 416 747 4013

Website: <http://www.csagroup.org/us/en/home>

Email: Benjamin.Barker@csagroup.org

Accreditation Number:	06001
Initial Accreditation Date:	2005-01-06
Reaccreditation Date:	2017-05--22
Accreditation Expiry Date:	2021-01-06
Accreditation Standards:	ISO/IEC 17020:2012 SCC Requirements and Guidance - Inspection Body Accreditation Program
Accreditation Sub-programs:	SPE-1000 Field Evaluation/Special Inspection SPE-3000 Field Evaluation/Special Inspection

Additional Critical/Key Locations:


Location	Country	Address	City
A	Canada	1707-94 Street North West Edmonton, AB T6N 1E6	Edmonton
B	Canada	865 Ellingham Avenue Pointe Claire, PQ H9R 5E8	Pointe Claire
C	Canada	13799 Commerce Parkway Richmond, BC V6V 2N9	Richmond
D	USA	5970 Fairview Road Suite 722 Charlotte, NC 28210	Charlotte
E	USA	8501 East Pleasant Valley Road Cleveland, OH 44131-5575	Cleveland
F	USA	2860 Glider Dr	Plano



Location	Country	Address	City
		Plano, TX 75074Arlington, TX 76018	
G	USA	34 Bunsen Irvine, CA 92618	Irvine

SPE-1000 Field Evaluation/Special Inspection

Inspection Label:



Note: The label presented above is in accordance with CSA-SPE-1000 and is effective as of April 01, 2015.

Scope of Accreditation:

The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:

As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding:

- wire and cable products;
- wiring devices;
- equipment for use in hazardous locations;
- medical electrical equipment and systems;
- components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;
- equipment connected to line voltage in excess of 46 kV;
- manlifts, elevators, climb assists and similar systems (other than their associated control panels); and
- any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone).

*Special inspection/field evaluation only applies to equipment that is capable of being connected



to the supply in accordance with the Canadian Electrical Code, Part I.

Product inspected to CSA SPE-1000 between April 1st, 2010 and April 1st, 2015 was labeled in accordance with CSA-SPE-1000 as represented by the label below.



Product inspected to CSA SPE-1000 prior to April 1st, 2010 was labeled in accordance with CSA-SPE-1000-99 as represented by the label below.



SPE-3000 Field Evaluation/Special Inspection

Inspection label



Scope of Accreditation:



The performing of field evaluations/special inspections and the application of approval labels on medical-electrical equipment (MEE) and medical-electrical systems (MES)[†] in accordance with all of the following:

As identified in the scope of CSA SPE-3000 Model Code for the field evaluation/special inspection of medical electrical equipment and systems, but excluding the following product categories at this time:

- a) cosmetic and hygiene equipment;
- b) X-ray equipment and systems;
- c) MRIs and CT scans; and
- d) laser equipment.

[†]The definitions for Medical electrical equipment (MEE) and Medical electrical system (MES) can be found in SPE-3000-15 Section 3 Definitions.