

INSPECTION BODY ACCREDITATION PROGRAM (IBAP) Scope of Accreditation

Accredited Legal Entity: QPS Evaluation Services, Inc.

Contact Name: Nick Maalouf

Address: 81 Kelfield Street, Unit 8

Toronto, ON M9W 5A3

Telephone: +1 416 241 8857

Fax: +1 416 241 0682

Website: http://www.qps.ca

Email: nmaalouf@qps.ca


Accreditation Number:	06005
Initial Accreditation Date:	2004-11-29
Reaccreditation Date:	2017-04-12
Accreditation Expiry Date:	2020-11-29
Accreditation Standards:	ISO/IEC 17020:2012 SCC Requirements and Guidance - Inspection Body Accreditation Program
Accreditation Sub-programs	SPE-1000 Field Evaluation/Special Inspection SPE-3000 Field Evaluation/Special Inspection

SPE-1000 Field Evaluation/Special Inspection

Inspection Label:







Note: The label presented above is in accordance with CSA-SPE-1000 and is effective as of April 01, 2010.

Scope of Accreditation:

The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:

As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding:

- a) wire and cable products;
- b) wiring devices;
- c) equipment for use in hazardous locations;
- d) medical electrical equipment and systems;
- e) components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;
- f) equipment connected to line voltage in excess of 46 kV;
- g) manlifts, elevators, climb assists and similar systems (other than their associated control panels); and
- h) any equipment that is not permitted to be field evaluated as directed by an AHJ (such as aircleaning equipment that intentionally produces ozone).

Product inspected prior to April 01, 2010 was labeled in accordance with CSA-SPE-1000-99 as represented by the labels below.




SPE-3000 Field Evaluation/Special Inspection

Inspection label



^{*}Special inspection/field evaluation only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.





Scope of Accreditation:

The performing of field evaluations/special inspections and the application of approval labels on medical-electrical equipment (MEE) and medical-electrical systems (MES)⁺ in accordance with all of the following:

As identified in the scope of CSA SPE-3000 Model Code for the field evaluation/special inspection of medical electrical equipment and systems, but excluding the following product categories at this time:

- a) cosmetic and hygiene equipment;
- b) X-ray equipment and systems;
- c) MRIs and CT scans; and
- d) laser equipment.

+The definitions for Medical electrical equipment (MEE) and Medical electrical system (MES) can be found in SPE-3000-15 Section 3 Definitions.

